

Syncro Bit Switch Configuration

Cabinet Bit switch Configuration

Switch	Output	Description
1	On	Temperature range -24°C
2	On	Temperature range -20°C
3	On	Temperature range 0°C
4	On	Temperature range +2°C
5	On	PEV shut during defrost
	Off	PEV open during defrost
6	On	600 Communications Baud rate
	Off	9600 Communications Baud rate
7	On	EPR not fitted
	Off	EPR fitted
8	On	Self test On
	Off	Self test Off

Cold Store Bit switch Configuration

	Temp	Bit 1	Bit 2	Bit 3
Frozen Food	-23°C	Off	On	On
LTM&P	-18°C	On	Off	On
Meat Chiller	-1°C	Off	Off	On
Provisions	+3°C	On	On	Off
Produce	+8°C	Off	On	Off
Fish	+2°C	On	Off	Off

Switch	Output	Description
Bit 5	On	PEV shut during defrost
	Off	PEV open during defrost
Bit 6	On	600 Communications Baud rate
	Off	9600 Communications Baud rate
Bit 7	N/A	Not used
Bit 8	On	Self test On
	Off	Self test Off

NOTE: NOT UNDER DOCUMENTATION CONTROL